


SUB-METERING SPATIAL REQUIREMENTS
Installation regulations for individual Cold Water Sub-Meters require 150mm clearance from the centre of each meter to other meters, walls or pipework.

SMARTLINK NOTES

- All drawings detail All Valve Industries meters (iTron TD8 and All Valve GSD5). A breech peice between couplings is supplied at time of dispatch from deFOX Industries. Meters are not supplied by deFOX Industries.
- All drawings detail manifolds with a 25mm Ø as standard. Other Ø manifolds are available upon request. Large manifolds will increase the overall depth.

 SmartLink METERING SYSTEMS	Project SmartLink	Model No. Spatial 5-6.HCWMF.25	Date of issue 20/06/2025	
	Client	Description 5 to 6 Hot & Cold Water Sub-Metering Frame	Scale	
	Notes • All measurements are in mm.	Contact	Created by Arin de Mestre	Sheet 1/2
This drawing remains the property of deFOX Industries Pty Ltd and may not be reproduced in full or part without the written consent of deFOX Indsutries.				
Rev.				

