


**SUB-METERING SPATIAL REQUIREMENTS**

Installation regulations for individual Cold Water Sub-Meters require 150mm clearance from the centre of each meter to other meters, walls or pipework. The above dimensions are specific to this meter setup.

|  |                             |  |                                   |      |
|--|-----------------------------|--|-----------------------------------|------|
|  <p><b>SmartLink</b><br/>METERING SYSTEMS</p>                       | Project<br><b>SmartLink</b> | Model No.<br><b>Spatial 2.HCWMF.NoTVPRV.25</b>                       | Date of issue<br><b>9/02/2026</b> |      |
|  | Client                      | Description<br><b>2 Hot &amp; Cold Water Frame - No TV &amp; PRV</b> | Scale<br><b>1:8</b>               |      |
| Notes<br>• All measurements are in mm.   | Contact                     | Created by<br><b>Arin de Mestre</b>                                  | Sheet<br><b>1/1</b>               | Rev. |
| This drawing remains the property of deFOX Industries Pty Ltd and may not be reproduced in full or part without the written consent of deFOX Industries. |                             |  |                                   |      |