


**SUB-METERING SPATIAL REQUIREMENTS**  
Installation regulations for individual Cold Water Sub-Meters require 150mm clearance from the centre of each meter to other meters, walls or pipework.

**SMARTLINK NOTES**

- All drawings detail All Valve Industries meters (iTron TD8 and All Valve GSD5). A breech peice between couplings is supplied at time of dispatch from deFOX Industries. Meters are not supplied by deFOX Industries.
- All drawings detail manifolds with a 25mm Ø as standard. Other Ø manifolds are available upon request. Large manifolds will increase the overall depth.

<div> <b>SmartLink</b> — METERING SYSTEMS —</div> <div>Notes<ul style="list-style-type: none"><li>• All measurements are in mm.</li></ul></div>	Project <b>SmartLink</b>	Model No. <b>Spatial 3-4.CWMF.25</b>	Date of issue <b>20/06/2025</b>	
	Client	Description <b>3 to 4 Cold Water Sub-Metering Frame</b>	Scale <b>1:20</b>	
	Contact	Created by <b>Arin de Mestre</b>	Sheet <b>1/1</b>	Rev.
This drawing remains the property of deFOX Industries Pty Ltd and may not be reproduced in full or part without the written consent of deFOX Indsutries.				