


SUB-METERING SPATIAL REQUIREMENTS

Installation regulations for individual Cold Water Sub-Meters require 150mm clearance from the centre of each meter to other meters, walls or pipework. The above dimensions are specific to this meter setup.

 <p>SmartLink — METERING SYSTEMS —</p> <p>Notes</p> <ul style="list-style-type: none"> All measurements are in mm. 	Project SmartLink	Model No. Spatial 5.HCWMF.25	Date of issue 5/02/2026	
	Client	Description 5 Hot & Cold Water Frame - Full	Scale 1:10	
	Contact	Created by Arin de Mestre	Sheet 1/1	Rev.
This drawing remains the property of deFOX Industries Pty Ltd and may not be reproduced in full or part without the written consent of deFOX Industries.				