



SUB-METERING SPATIAL REQUIREMENTS

Installation regulations for individual Cold Water Sub-Meters require 150mm clearance from the centre of each meter to other meters, walls or pipework. The above dimensions are specific to this meter setup.



Notes
 • All measurements are in mm.

Project SmartLink	Model No. Spatial 3.HCWMF.25	Date of issue 5/02/2026	
Client	Description 3 Hot & Cold Water Frame - Full	Scale 1:7	
Contact	Created by Arin de Mestre	Sheet 1/1	Rev.

This drawing remains the property of deFOX Industries Pty Ltd and may not be reproduced in full or part without the written consent of deFOX Industries.