


SUB-METERING SPATIAL REQUIREMENTS

Installation regulations for individual Cold Water Sub-Meters require 150mm clearance from the centre of each meter to other meters, walls or pipework. The above dimensions are specific to this meter setup.

| | | | |
|--|-----------------------------|---|-----------------------------------|
|  SmartLink — METERING SYSTEMS — | Project SmartLink | Model No. Spatial 9.HCWMF.NoPRV.25 | Date of issue 8/02/2026 |
| | Client | Description 9 Hot & Cold Water Frame - No PRV | Scale 1:8 |
| | Contact | Created by Arin de Mestre | Sheet 1/1 |
| Notes • All measurements are in mm. | | | |
| This drawing remains the property of deFOX Industries Pty Ltd and may not be reproduced in full or part without the written consent of deFOX Industries. | | | |