


SUB-METERING SPATIAL REQUIREMENTS

Installation regulations for individual Cold Water Sub-Meters require 150mm clearance from the centre of each meter to other meters, walls or pipework. The above dimensions are specific to this meter setup.

 <p>SmartLink — METERING SYSTEMS —</p> <p>Notes</p> <ul style="list-style-type: none"> All measurements are in mm. 	Project	SmartLink	Model No.	Spatial 2.CWMF.25	Date of issue	2/02/2026	
	Client		Description	2 Cold Water Frame - Full	Scale	1:8	
	Contact		Created by	Arin de Mestre	Sheet	1/1	Rev.
This drawing remains the property of deFOX Industries Pty Ltd and may not be reproduced in full or part without the written consent of deFOX Industries.							