


**SUB-METERING SPATIAL REQUIREMENTS**

Installation regulations for individual Cold Water Sub-Meters require 150mm clearance from the centre of each meter to other meters, walls or pipework. The above dimensions are specific to this meter setup.

 <b>SmartLink</b> METERING SYSTEMS	Project <b>SmartLink</b>	Model No. <b>Spatial 4.HCWMF.NoPRV.25.Vert</b>	Date of issue <b>8/02/2026</b>	
	Client	Description <b>4 Hot &amp; Cold Water Vert Frame - No PRV</b>	Scale <b>1:10</b>	
	Contact	Created by <b>Arin de Mestre</b>	Sheet <b>1/1</b>	Rev.
Notes • All measurements are in mm.				
This drawing remains the property of deFOX Industries Pty Ltd and may not be reproduced in full or part without the written consent of deFOX Industries.				