


SUB-METERING SPATIAL REQUIREMENTS

Installation regulations for individual Cold Water Sub-Meters require 150mm clearance from the centre of each meter to other meters, walls or pipework. The above dimensions are specific to this meter setup.

 <p>SmartLink — METERING SYSTEMS —</p> <p>Notes</p> <ul style="list-style-type: none"> All measurements are in mm. 	Project SmartLink	Model No. Spatial 2.HCWMF.NoTVPRV.25.Vert	Date of issue 9/02/2026
	Client	Description 2 Hot & Cold Water Vert Frame - No TV & PRV	Scale 1:10
	Contact	Created by Arin de Mestre	Sheet 1/1
This drawing remains the property of deFOX Industries Pty Ltd and may not be reproduced in full or part without the written consent of deFOX Industries.			