


SUB-METERING SPATIAL REQUIREMENTS

Installation regulations for individual Cold Water Sub-Meters require 150mm clearance from the centre of each meter to other meters, walls or pipework. The above dimensions are specific to this meter setup.

 <p>SmartLink METERING SYSTEMS</p>	Project SmartLink	Model No. Spatial 1.HCWMF.NoTVPRV.25	Date of issue 8/02/2026
	Client	Description 1 Hot & Cold Water Frame - No TV & PRV	Scale 1:8
Notes • All measurements are in mm.	Contact	Created by Arin de Mestre	Sheet 1/1
This drawing remains the property of deFOX Industries Pty Ltd and may not be reproduced in full or part without the written consent of deFOX Industries.			